



CATAWBA COUNTY ENVIRONMENTAL HEALTH
NO GPS AT FINAL INSPECTIONS
BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>		<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
2658-04							
AUTH-10-2016-078173	9230 COOKSVILLE RD, VALE NC 28168	Authorization to Construct	Final	New Septic		Randy Ross	11/17/2016
	EHINSP-342763	EH Septic Installation	Approved	11/17/2016	11/14/2016	Approved	Randy Ross
2667-03							
WELL-04-2022-169062	9633 MULL RD, VALE NC 28168	Well	Final	New Well		Eric Price	06/07/2023
	EHINSP-571923	EH Well Grouting	Approved	05/16/2022	05/10/2022	Approved	Eric Price
	EHINSP-643974	EH Well Head	Approved	06/07/2023	06/07/2023	Approved	Bryan Forsee
	EHINSP-571382	EH Well Record Received	Approved	05/11/2022	05/11/2022	Approved	EH Admin
2667-04							
AUTH-02-2016-069101	4075 WISE RD, VALE NC 28168	Authorization to Construct	Final	New Septic		Randy Ross	10/21/2016
	EHINSP-339543	EH Septic Installation	Approved	11/17/2016	10/17/2016	Approved	Randy Ross
2669-02							
WELL-06-2022-174163	8515 BRITTAIN RD, VALE NC 28168	Well	Final	New Well		Blake Perkins	11/07/2022
	EHINSP-600420	EH Well Grouting	Approved	10/20/2022	10/20/2022	Approved	Blake Perkins
	EHINSP-603661	EH Well Head	Approved	11/07/2022	11/07/2022	Approved	Cheyenne Morgan
	EHINSP-600711	EH Well Record Received	Approved	10/24/2022	10/24/2022	Approved	Blake Perkins
2687-01							
WELL-07-2022-175033	3777 AMBER DR, VALE NC 28168	Well	Final	New Well		Blake Perkins	12/16/2022
	EHINSP-608778	EH Well Grouting	Approved	12/06/2022	12/06/2022	Approved	Blake Perkins
	EHINSP-610739	EH Well Head	Approved	12/15/2022	12/15/2022	Approved	Blake Perkins
	EHINSP-610812	EH Well Record Received	Approved	12/16/2022	12/16/2022	Approved	EH Admin
2687-03							



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>		<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
2687-03							
WELL-05-2022-171503	4194 BANOAK RD, VALE NC 28168	Well	Final	New Well		Cheyenne Morgan	03/14/2023
	EHINSP-617258	EH Well Grouting	Approved	01/24/2023	01/24/2023	Approved	Cheyenne Morgan
	EHINSP-626139	EH Well Head	Approved	03/14/2023	03/14/2023	Approved	Cheyenne Morgan
	EHINSP-617110	EH Well Record Received	Approved	01/25/2023	01/25/2023	Approved	EH Admin

2688-04							
AUTH-02-2023-188973	6905 W NC 10 HWY, VALE NC 28168	Authorization to Construct	Final	New Septic		Blake Perkins	06/15/2023
	EHINSP-645950	EH Septic Installation	Approved	06/14/2023	06/14/2023	Approved	Blake Perkins

2698-02							
AUTH-05-2016-072621	3455 Plateau RD, Newton NC 28658	Authorization to Construct	Final	New Septic		Randy Ross	10/11/2016
	EHINSP-338725	EH GPS Data Collection	Canceled		10/10/2016	Canceled	Randy Ross
	EHINSP-338724	EH Septic Installation	Approved	11/17/2016	10/10/2016	Approved	Randy Ross

2699-18							
AUTH-10-2023-206873	5340 S NC 127 HWY, HICKORY NC 28602	Authorization to Construct	Final	Other			11/10/2023
	EHINSP-676678	EH Septic Installation	Approved	11/10/2023	11/03/2023	Approved	

3608-01							
AUTH-06-2016-073786	4535 ATHENS DR, NEWTON NC 28658	Authorization to Construct	Final	Expansion		Randy Ross	10/19/2016
	EHINSP-339554	EH Septic Installation	Approved	11/17/2016	10/18/2016	Approved	Randy Ross

3608-02



CATAWBA COUNTY ENVIRONMENTAL HEALTH
NO GPS AT FINAL INSPECTIONS
BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>		<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
3608-02							
AUTH-02-2023-189674	4147 W NC 10 HWY, HICKORY NC 28602	Authorization to Construct	Final	Repair/Expansion		Blake Perkins	03/22/2023
	EHINSP-627601	EH Septic Installation	Approved	03/20/2023	03/20/2023	Approved	Blake Perkins

3617-02							
WELL-10-2021-158931	3092 BLACKBURN BRIDGE RD, LINCOLNTON NC 28092	Well	Final	New Well		Cheyanne Morgan	02/02/2023
	EHINSP-617732	EH Well Grouting	Approved	01/13/2023	01/13/2023	Approved	Cheyanne Morgan
	EHINSP-617733	EH Well Head	Approved	01/23/2023	01/23/2023	Approved	Cheyanne Morgan
	EHINSP-618629	EH Well Record Received	Approved	02/02/2023	02/02/2023	Approved	EH Admin

3617-03							
WLS2007-01615	4119 POTTS CREEK RD, LINCOLNTON NC	Well	Final	New Well		Jason Boyd	03/26/2008
	200902021647440830	EH Well Grouting	Approved	03/26/2008	03/26/2008	Approved	Jason Boyd
	Done By: JB Notes:						
	INSP-144308	EH Well Head	Approved	03/26/2008	03/26/2008	Approved	Jason Boyd
	INSP-144309	EH Well Record Received	Approved	06/25/2008	06/25/2008	Approved	EH Admin

3627-07							
AUTH-04-2017-084359	2407 ELBOW RD, NEWTON NC 28658	Authorization to Construct	Final	New Septic		Jason Boyd	09/03/2019
	EHINSP-381096	EH GPS Data Collection	Follow Up Required	12/22/2017	12/22/2017	Follow Up Required	Jason Boyd
	No house or well at time of inspection. Will do site plan once house is in place.						
	EHINSP-381097	EH Septic Installation	Approved	12/22/2017	12/22/2017	Approved	Jason Boyd

3636-11



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>	<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
3636-11						
WELL-2-10-4785	604 SALEM CHURCH RD, Maiden NC 28650	Well	Final	New Well	Luke Sears	04/22/2020
INSP-31752	EH Well Grouting	Approved		03/12/2010 03/12/2010	Approved	Luke Sears
EHINSP-474373	EH Well Head	Approved		04/22/2020 04/22/2020	Approved	Eric Price
INSP-39245	EH Well Record Received	Approved		11/10/2010 11/10/2010	Approved	EH Admin
	ROY PRICE					

3638-13						
WELL-07-2021-154601	1862 TRIPLETTS FARM RD, NEWTON NC 28658	Well	Final	New Well	Cheyenne Morgan	04/20/2023
EHINSP-549684	EH Well Grouting	Approved		12/10/2021 12/10/2021	Approved	Cheyenne Morgan
EHINSP-600923	EH Well Head	Failed		10/14/2022 10/14/2022	Failed	Cheyenne Morgan
	Well head missing screw for seal, wire conduit not sealed, and no threadless tap.					
EHINSP-633557	EH Well Head	Approved		04/20/2023 04/19/2023	Approved	Cheyenne Morgan
EHINSP-549463	EH Well Record Received	Approved		12/13/2021 12/13/2021	Approved	EH Admin

3639-10						
AUTH-05-2019-116184	1968 JARRETT FARM RD, NEWTON NC 28658	Authorization to Construct	Final	Repairs	Dean Evans	11/18/2019
EHINSP-456660	EH Septic Installation	Approved		11/18/2019 11/14/2019	Approved	Dean Evans

3647-08						
AUTH-10-2020-140044	3381 CORKY LN, NEWTON NC 28658	Authorization to Construct	Final	Repairs	Dean Evans	11/04/2020
EHINSP-496836	EH GPS Data Collection	Canceled		11/04/2020 11/03/2020	Canceled	Dean Evans
EHINSP-496835	EH Septic Installation	Approved		11/04/2020 11/03/2020	Approved	Dean Evans

3648-08



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#


<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>		<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
3648-08							
AUTH-10-2019-124094	2336 DELLINGER DR, NEWTON NC 28658	Authorization to Construct	Final	New Septic		Dean Evans	10/23/2020
	EHINSP-495623	EH GPS Data Collection	Canceled	10/23/2020	10/21/2020	Canceled	Dean Evans
	EHINSP-495622	EH Septic Installation	Approved	10/23/2020	10/21/2020	Approved	Dean Evans

3656-14							
AUTH-09-2020-138148	4820 RAINEY LN, MAIDEN NC 28650	Authorization to Construct	Final	New Septic		Randy Ross	06/08/2022
	EHINSP-507953	EH GPS Data Collection	Canceled	02/18/2021	12/03/2020	Canceled	Randy Ross
	EHINSP-507952	EH Septic Installation	Approved	02/18/2021	12/03/2020	Approved	Randy Ross

3659-14							
WELL-08-2015-063545	2498 S NC 16 HWY, NEWTON NC 28658	Well	Final	Replacement		Jason Boyd	01/30/2017
	EHINSP-345929	EH Well Grouting	Approved	12/28/2016	12/28/2016	Approved	Jason Boyd
	EHINSP-347667	EH Well Head	Approved	01/20/2017	01/20/2017	Approved	Jason Boyd
	EHINSP-346036	EH Well Record Received	Approved	12/29/2016	12/29/2016	Approved	EH Admin

3666-01							
WELL-03-2022-167350	3166 E MAIDEN RD, MAIDEN NC 28650	Well	Final	New Well		Blake Perkins	10/28/2022
	EHINSP-593688	EH Well Grouting	Approved	09/20/2022	09/20/2022	Approved	Blake Perkins
	EHINSP-601675	EH Well Head	Failed	10/27/2022	10/27/2022	Failed	Cheyenne Morgan
	No pump tag						
	EHINSP-602072	EH Well Head	Approved	10/28/2022	10/28/2022	Approved	Cheyenne Morgan
	EHINSP-601928	EH Well Record Received	Approved	10/28/2022	10/27/2022	Approved	EH Admin

3666-04



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>	<u>WORK CLASS</u>	<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>		
3666-04							
WELL-01-2020-127001	4988 CALEB RD, MAIDEN NC 28650	Well	Final	New Well	03/13/2023		
	EHINSP-480365	EH GPS Data Collection	Canceled	06/11/2020	05/07/2020	Canceled	
	EHINSP-480364	EH Well Head	Approved	06/11/2020	06/05/2020	Approved	Randy Ross
	EHINSP-480395	EH Well Record Received	Approved	06/11/2020	06/11/2020	Approved	EH Admin
WELL-10-2016-077719	3814 E MAIDEN RD, MAIDEN NC 28650	Well	Final	New Well	Jason Boyd	04/03/2017	
	EHINSP-351416	EH Well Grouting	Approved	02/27/2017	02/24/2017	Approved	Jason Boyd
	Well driller called for grout at 11:15. Unable to make it Friday afternoon and they were concerned it may cave in around casing.						
	EHINSP-354494	EH Well Head	Approved	03/29/2017	03/24/2017	Approved	Jason Boyd
	EHINSP-354974	EH Well Record Received	Approved	04/03/2017	04/03/2017	Approved	EH Admin
WELL-11-2020-141290	4936 CALEB RD, MAIDEN NC 28650	Well	Final	New Well	Randy Ross	09/21/2022	
	EHINSP-593805	EH Well Grouting	Approved	09/20/2022	10/18/2021	Approved	Randy Ross
	EHINSP-593628	EH Well Head	Approved	09/20/2022	09/20/2022	Approved	Blake Perkins
	EHINSP-543303	EH Well Record Received	Approved	11/01/2021	11/01/2021	Approved	EH Admin

3678-04



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>		<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
3678-04							
AUTH-02-2022-166414	3195 TIMBER RUN LN, MAIDEN NC 28650	Authorization to Construct	Final	Other		Steven Price	01/24/2023
EHINSP-616716	EH Septic Installation said made changes but had not.	Failed		01/23/2023	12/12/2022	Failed	Steven Price
EHINSP-616718	EH Septic Installation engineer sent pressure test approval	Approved	EH	01/23/2023	01/20/2023	Approved	Steven Price
EHINSP-616715	EH Septic Installation failed additional inspections on 11/29, 12/5, and 12/8. 12/9 met surveyor and they marked supply line easement. some of supply lines were located outside of easement. supply line for lot 73 on lot 72a at offsite areas.	Failed		01/23/2023	12/09/2022	Failed	Steven Price
EHINSP-616714	EH Septic Installation supply line network installed illegally at an unknown date without EH inspections by someone other than a septic installer. utilities installer gave robbie their certification #. Holes dug every 50 to 100 ft along supply lines to see pipe type. Pipe type is not sch40 pvc and unacceptable according to pictures sent to engineer David Decarron. supply lines appear to be installed outside of septic easement.	Failed		01/23/2023	11/28/2022	Failed	Steven Price
EHINSP-616717	EH Septic Installation received as built showing pipes located within easement. still need approval letter from engineer on pressure test of lines. still need to add pressure release valves on supply lines.	Failed		01/23/2023	12/19/2022	Failed	Steven Price
AUTH-04-2016-070967	4532 CAYTON DR, MAIDEN NC 28650	Authorization to Construct	Final	New Septic		Megen McBride	11/29/2016
EHINSP-343454	EH Electrical/Alarm	Approved		11/28/2016	11/28/2016	Approved	Megen McBride
EHINSP-341645	EH Septic Installation Checked Dellinger Tanks, (3) 133' lines IQ4W with Kevin Hallman #2025 on 11/4/16. Need to set pressure head and test alarm. Using a Goulds WEO 312 1/3 HP pump.	Approved		11/08/2016	11/04/2016	Approved	Jason Boyd
EHINSP-343453	EH Septic Pump Final	Approved		11/28/2016	11/28/2016	Approved	Megen McBride
AUTH-3-12-25872	4571 LITTLE MOUNTAIN RD, CATAWBA NC 28609-	Authorization to Construct	Final	New Septic		Robbie Phelps	08/04/2017
EHINSP-218888	EH Final	Approved		04/16/2012	04/13/2012	Approved	Robbie Phelps
EHINSP-218887	EH Septic Installation	Approved		04/16/2012	04/13/2012	Approved	Robbie Phelps



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>		<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
3678-04							
WELL-01-2018-094118	4475 NORTH WYNSWEPT DR, MAIDEN NC 28650	Well	Final	New Well		Jason Boyd	06/18/2018
	EHINSP-390175	EH Well Grouting	Approved	04/06/2018	04/06/2018	Approved	Jason Boyd
	EHINSP-396986	EH Well Head	Failed	06/13/2018	06/12/2018	Failed	Jason Boyd
	No pump or sanitary seal installed at time of inspection						
	EHINSP-397522	EH Well Head	Approved	06/18/2018	06/15/2018	Approved	Jason Boyd
	EHINSP-397533	EH Well Record Received	Approved	06/18/2018	06/18/2018	Approved	EH Admin
WELL-01-2018-094124	4487 NORTH WYNSWEPT DR, MAIDEN NC 28650	Well	Final	New Well		Jason Boyd	06/18/2018
	EHINSP-390174	EH Well Grouting	Approved	04/06/2018	04/06/2018	Approved	Jason Boyd
	EHINSP-396998	EH Well Head	Failed	06/13/2018	06/12/2018	Failed	Jason Boyd
	No well tag or pump tag						
	EHINSP-397521	EH Well Head	Approved	06/18/2018	06/15/2018	Approved	Jason Boyd
	EHINSP-397534	EH Well Record Received	Approved	06/18/2018	06/18/2018	Approved	EH Admin
WELL-06-2016-073811	4532 CAYTON DR, MAIDEN NC 28650	Well	Final	New Well			11/29/2016
	EHINSP-343495	EH GPS Data Collection	None			None	
	EHINSP-343451	EH Well Grouting	Approved	11/28/2016	07/13/2016	Approved	Jason Boyd
	EHINSP-343494	EH Well Head	Approved	11/29/2016	11/29/2016	Approved	Megen McBride
	EHINSP-330680	EH Well Record Received	Approved	07/14/2016	07/14/2016	Approved	EH Admin
3687-02							
WELL-05-2020-133048	3644 KIMBER LN, SHERRILLS FORD NC 28673	Well	Final	New Well		Jason Boyd	02/03/2021
	EHINSP-503046	EH Well Grouting	Approved	01/08/2021	01/06/2021	Approved	Jason Boyd
	EHINSP-506183	EH Well Head	Approved	02/03/2021	02/02/2021	Approved	Jason Boyd
	EHINSP-504071	EH Well Record Received	Approved	01/19/2021	01/19/2021	Approved	EH Admin
3689-04							



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

PERMIT#	ADDRESS	PERMIT TYPE	WORK CLASS	INSPECTOR NAME	FINALED DATE
3689-04					
AUTH-5-10-7499	1846 MATHIS CHURCH RD, Catawba NC 28609	Authorization to Construct	Final New Septic	Admin Admin	01/11/2017
	INSP-55949	EH Septic Installation	None	None	Admin Admin

3696-02					
AUTH-01-2016-068007	6662 GOOSE POINT DR, DENVER NC 28037	Authorization to Construct	Final New Septic	Jason Boyd	04/18/2017
	EHINSP-315370	EH GPS Data Collection	Not Ready	Not Ready	Jason Boyd
	EHINSP-315369	EH Septic Installation	Approved	Approved	Jason Boyd
<p>Checked septic and pump tank with Kevin Hallman 1/11/16. Dellinger 1500 gallon septic and pump tank dated 12/7 and 11/9/15 Tanks installed prior to grading of house due to access around house for tank truck.</p> <p>Checked drain field and supply line with installer Richard Abernethy on 11/21/16.</p> <p>****NEED TO SET PRESSURE HEAD AND ALARM PRIOR TO ISSUANCE OF OP*****</p> <p>Checked alarm and set pressure head with Chris Fritz on 4/17/17.</p>					

3696-04					
AUTH-07-2016-075125	6600 LINEBERGER RD, DENVER NC 28037	Authorization to Construct	Final Expansion		10/26/2016
	EHINSP-340304	EH GPS Data Collection	Canceled	Canceled	
	EHINSP-340305	EH Septic Installation	None	None	

3696-08					
WELL-01-2020-127240	4478 POWER DR, SHERRILLS FORD NC 28673	Well	Final New Well	Robbie Phelps	11/09/2020
	EHINSP-494719	EH Well Head	Approved	Approved	Robbie Phelps
	EHINSP-493542	EH Well Record Received	Approved	Approved	EH Admin

3697-20



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>	<u>WORK CLASS</u>	<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>		
3697-20							
WELL-08-2023-201740	6972 VINEWOOD RD, SHERRILLS FORD NC 28673	Well	Final	Replacement	Bryan Forsee	10/03/2023	
EHINSP-665574	EH Well Grouting	Approved		09/20/2023	09/19/2023	Approved	Bryan Forsee
EHINSP-666913	EH Well Head	Approved		09/26/2023	09/28/2023	Approved	Bryan Forsee
EHINSP-666445	EH Well Record Received	Approved		09/25/2023	09/25/2023	Approved	EH Admin
3698-01							
WELL-09-2018-105588	2450 CRAPIE DR, SHERRILLS FORD NC 28673	Well	Final	New Well	Jason Boyd	05/07/2019	
EHINSP-431918	EH GPS Data Collection	Canceled		05/07/2019	05/07/2019	Canceled	Jason Boyd
EHINSP-409338	EH Well Grouting	Approved		10/05/2018	10/02/2018	Approved	Jason Boyd
EHINSP-426487	EH Well Head	Follow Up Required		03/20/2019	03/20/2019	Follow Up Required	Jason Boyd
3/19/19 Took samples at request of owner. No well tag or pump tag on well head. Left message for owner to let Jeff Speagle know.							
EHINSP-431919	EH Well Head	Approved		05/07/2019	05/06/2019	Approved	Jason Boyd
EHINSP-431978	EH Well Record Received	Approved		05/07/2019	05/07/2019	Approved	EH Admin
3698-03							
WELL-01-2022-163612	3303 MOUNTAIN CREEK DR, SHERRILLS FORD NC 28673	Well	Final	New Well	Jason Boyd	07/26/2022	
EHINSP-565866	EH Well Grouting	Approved		04/07/2022	04/05/2022	Approved	Jason Boyd
EHINSP-580041	EH Well Head	Approved		06/28/2022	06/28/2022	Approved	Cheyenne Morgan
EHINSP-583698	EH Well Record Received	Approved		07/26/2022	07/26/2022	Approved	EH Admin
WELL-01-2022-163670	3229 CREEK BEND CT, SHERRILLS FORD NC 28673	Well	Final	New Well	Robbie Phelps	05/25/2023	
EHINSP-626803	EH Well Head	Approved		03/16/2023	03/16/2023	Approved	Robbie Phelps
EHINSP-639024	EH Well Record Received	Approved		05/16/2023	05/16/2023	Approved	EH Admin
3699-01							



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>	<u>WORK CLASS</u>	<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
3699-01					
WELL-7-11-19920	1795 KESTREL VALLEY LN, Catawba NC 28609	Well	Final	New Well	Jason Boyd 08/02/2021
INSP-160839	EH Well Grouting	Approved	08/29/2011	08/29/2011	Approved Jason Boyd
EHINSP-529400	EH Well Head	Approved	07/27/2021	07/21/2021	Approved Jason Boyd
INSP-160843	EH Well Record Received	Approved	10/12/2011	10/12/2011	Approved EH Admin

3700-05					
AUTH-06-2022-173232	1516 WHITE EAGLE RANCH RD, HICKORY NC 28602	Authorization to Construct	Final	New Septic	Eric Price 08/08/2023
EHINSP-580076	EH GPS Data Collection	Follow Up Required	07/04/2022	06/27/2022	Follow Up Required Eric Price
EHINSP-580077	EH Septic Installation	Follow Up Required	07/04/2022	06/27/2022	Follow Up Required Eric Price
EHINSP-656671	EH Septic Installation	Approved	08/07/2023	07/14/2023	Approved Blake Perkins

3701-17					
AUTH-01-2023-187583	1733 MAGNUM RD, HICKORY NC 28602	Authorization to Construct	Final	Repair/Expansion	Blake Perkins 03/13/2023
EHINSP-625148	EH Septic Installation	Approved	03/09/2023	03/09/2023	Approved Blake Perkins

3705-19					
AUTH-01-2020-127570	4029 6TH ST DR NW, HICKORY NC 28601	Authorization to Construct	Final	Repairs	Dean Evans 03/03/2020
EHINSP-468262	EH GPS Data Collection	Canceled	03/03/2020	02/20/2020	Canceled Dean Evans
EHINSP-468261	EH Septic Installation	Approved	03/03/2020	03/03/2020	Approved Dean Evans

3705-20




CATAWBA COUNTY ENVIRONMENTAL HEALTH
NO GPS AT FINAL INSPECTIONS
BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>		<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
3705-20							
WLS2007-00440A	4240 4TH ST LN NW, HICKORY NC	Authorization to Construct	Final	New Septic		Mike Cash	08/14/2009
	EHINSP-331780	EH Septic/OP Final (Import)	Approved	07/27/2016	08/14/2009	Approved	Mike Cash
	information provided by Mike Cash to final out case.						
3714-08							
AUTH-03-2016-070552	4108 16TH ST NE, HICKORY NC 28601	Authorization to Construct	Final	Repairs		Steven Price	04/04/2016
	EHINSP-321143	EH GPS Data Collection	Canceled	03/30/2016		Canceled	Steven Price
	EHINSP-321144	EH Septic Installation	None	03/30/2016		None	Steven Price
3720-11							
AUTH-01-2023-187750	2264 MILTON ST, NEWTON NC 28658	Authorization to Construct	Final	New Septic		Dean Evans	08/25/2023
	EHINSP-659700	EH GPS Data Collection	Canceled	08/23/2023	08/18/2023	Canceled	Dean Evans
	EHINSP-659699	EH Septic Installation	Approved	08/23/2023	08/18/2023	Approved	
3720-15							
WELL-05-2018-099711	1192 Harper Lee DR, Newton NC 28658	Well	Final	New Well		Randy Ross	02/12/2019
	EHINSP-422374	EH GPS Data Collection	Canceled	02/12/2019	02/12/2019	Canceled	Randy Ross
	EHINSP-401814	EH Well Grouting	Approved	07/30/2018	07/30/2018	Approved	Randy Ross
	EHINSP-422373	EH Well Head	Approved	02/12/2019	02/01/2019	Approved	Randy Ross
	EHINSP-404955	EH Well Record Received	Approved	08/28/2018	08/27/2018	Approved	EH Admin
3724-09							
AUTH-11-2016-079252	2245 35TH AVE DR NE, HICKORY NC 28601	Authorization to Construct	Final	Repairs		Randy Ross	12/05/2016
	EHINSP-344026	EH Septic Installation	Approved	12/05/2016	11/23/2016	Approved	Randy Ross



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>		<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
3725-18							
WLS2006-01390	4364 25TH ST PL NE, HICKORY NC 200902171353043230	Well EH Well Grouting	Final Approved	New Well	11/09/2006	11/09/2006	Robbie Phelps Approved Robbie Phelps
	Done By: RP Notes:						
	EHINSP-233456	EH Well Head	Approved		11/14/2012	08/05/2019	Approved Randy Ross
	well head approved. shared well with 4375 25th St PL NE, Hickory per RR						
	INSP-139981	EH Well Record Received	Approved		12/20/2006	12/20/2006	Approved EH Admin
3730-09							
WELL-08-2022-177814	1451 WHITE OAK DR, NEWTON NC 28658	Well	Final	New Well			Cheyenne Morgan 10/26/2023
	EHINSP-618542	EH Well Grouting	Approved		02/01/2023	02/01/2023	Approved Cheyanne Morgan
	EHINSP-628167	EH Well Head	Approved		03/16/2023	03/16/2023	Approved Cheyanne Morgan
	EHINSP-673478	EH Well Record Received	Approved		10/26/2023	10/26/2023	Approved EH Admin
3735-12							
AUTH-12-2018-109210	4190 54TH AVE NE, HICKORY NC 28601	Authorization to Construct	Revoked	New Septic			Robbie Phelps 01/09/2020
	EHINSP-459930	EH Maintenance Contract Received	Approved		12/13/2019	12/12/2019	Approved Robbie Phelps
3735-15							
AUTH-08-2019-120959	6193 SULPHUR SPRINGS RD, HICKORY NC 28601	Authorization to Construct	Final	New Septic			Dean Evans 11/09/2022
	EHINSP-538394	EH Electrical/Alarm	Approved		09/28/2021	09/10/2021	Approved Dean Evans
	EHINSP-538391	EH GPS Data Collection	Canceled		09/28/2021	09/10/2021	Canceled Dean Evans
	EHINSP-538393	EH Septic Installation	Approved		09/28/2021	09/10/2021	Approved Dean Evans
	EHINSP-538395	EH Septic Pump Final	Approved		09/28/2021	09/10/2021	Approved Dean Evans



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>	<u>WORK CLASS</u>	<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>	
3735-15						
WLS2009-00654A	6091 EMORY LN, HICKORY NC	Authorization to Construct	Final	New Septic	Dean Evans	05/25/2021
	EHINSP-520666	EH Septic Installation	Approved	05/25/2021	05/12/2021	Approved Dean Evans

3743-09						
WELL-03-2016-070140	4288 JA YOUNT FARM RD, CONOVER NC 28613	Well	Final	New Well		12/14/2016
	EHINSP-344916	EH GPS Data Collection	None	12/14/2016		None
	EHINSP-323756	EH Well Grouting	Approved	04/29/2016	04/18/2016	Approved Steven Price
	EHINSP-344895	EH Well Head	Approved	12/13/2016	11/04/2016	Approved Steven Price
	EHINSP-323088	EH Well Record Received	Approved	04/22/2016	04/22/2016	Approved EH Admin

3745-16						
WELL-10-2021-159753	1817 GOSPEL DRIVEN WAY, CONOVER NC 28613	Well	Final	New Well	Steven Price	11/11/2022
	EHINSP-569083	EH Well Grouting	Approved	04/27/2022	04/26/2022	Approved Steven Price
	EHINSP-604691	EH Well Head	Approved	11/11/2022	11/11/2022	Approved Dean Evans
	EHINSP-569206	EH Well Record Received	Approved	04/28/2022	04/28/2022	Approved EH Admin

3752-07						
AUTH-07-2021-154141	3599 MULLIGAN DR NE, CONOVER NC 28613	Authorization to Construct	Final	Repairs	Dean Evans	09/21/2021
	EHINSP-537409	EH GPS Data Collection	Canceled	09/21/2021	09/16/2021	Canceled Dean Evans
	EHINSP-537410	EH Septic Installation	None		09/16/2021	None Dean Evans

3753-04



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>		<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
3753-04							
WELL-05-2017-086075	2862 VERDIE DR, CLAREMONT NC 28610	Well	Final	Repairs		Randy Ross	06/01/2017
EHINSP-360928	EH Well Grouting Installed liner 53' from surface and grouted entire length.	Approved		06/01/2017	05/31/2017	Approved	Randy Ross
EHINSP-360927	EH Well Head	Approved		06/01/2017	05/31/2017	Approved	Randy Ross
EHINSP-363052	EH Well Record Received	Approved		06/21/2017	06/21/2017	Approved	Randy Ross
3763-02							
WLS2005-00610	3986 CARPENTER COVE RD RD, CLAREMONT NC	Well	Final	New Well			05/30/2018
EHINSP-395621	EH GPS Data Collection	Canceled		05/30/2018	05/30/2018	Canceled	
EHINSP-381738	EH Well Grouting Grout was certified by well driller.	Approved		01/05/2018	10/11/2005	Approved	
INSP-48860	EH Well Head tried to do the well head at the septic final and the well house was locked/bolted shut. The house has not been built yet...so I couldn't knock on the door and speak to the owner.	Failed		02/25/2010	02/25/2010	Failed	Megen McBride
EHINSP-381739	EH Well Head tried to do the well head at the septic final and the well house was locked/bolted shut. The house has not been built yet...so I couldn't knock on the door and speak to the owner.	Failed		01/05/2018	02/25/2010	Failed	Megen McBride
EHINSP-381741	EH Well Head	Approved		01/05/2018	01/05/2018	Approved	Steven Price
EHINSP-381740	EH Well Record Received	Approved		01/05/2018	10/19/2005	Approved	EH Admin
3764-02							
AUTH-10-2016-078011	5186 CORBAN ST, CLAREMONT NC 28610	Authorization to Construct	Final	New Septic		Randy Ross	12/16/2016
EHINSP-342761	EH Septic Installation	Approved		11/17/2016	11/04/2016	Approved	Randy Ross
WELL-10-2016-078012	5186 CORBAN ST, CLAREMONT NC 28610	Well	Final	New Well		Randy Ross	12/16/2016
EHINSP-344695	EH Well Grouting	Approved		12/12/2016	12/12/2016	Approved	Randy Ross
EHINSP-345252	EH Well Head	Approved		12/16/2016	12/16/2016	Approved	Randy Ross
EHINSP-345221	EH Well Record Received	Approved		12/16/2016	12/16/2016	Approved	EH Admin



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>		<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
3764-03							
AUTH-02-2022-164804	5476 RIVER BEND RD, CLAREMONT NC 28610	Authorization to Construct	Revoked	Other		Dean Evans	03/16/2022
	EHINSP-607628	EH Septic Installation	Approved	12/01/2022	11/24/2022	Approved	Dean Evans
	EHINSP-607627	EH Septic Installation	Failed	12/01/2022	10/04/2022	Failed	Dean Evans
	*PLUMBER KNOCKED A HOLE IN THE MIDSEAM OF THE SEPTIC TANK DEEMING TANK UNUSABLE, COMPROMISING ITS STRUCTURE AND FUNCTIONALITY.						
AUTH-03-2022-167622	5476 RIVER BEND RD, CLAREMONT NC 28610	Authorization to Construct	Final	Other		Dean Evans	12/01/2022
	EHINSP-611097	EH Septic Installation	Approved	12/19/2022	11/24/2022	Approved	Dean Evans
	EHINSP-596662	EH Septic Installation	Failed	10/05/2022	10/04/2022	Failed	Dean Evans
	SEWER LINE ENTERS SEPTIC TANK IN WRONG LOCATION. SETIC TANK STRUCTUTRE COMPROMISED. NEED TO ABANDON TANK						
3771-11							
WELL-08-2021-155822	2073 PINETOP RIDGE RD, CATAWBA NC 28609	Well	Final	New Well		Dean Evans	02/24/2022
	EHINSP-559339	EH GPS Data Collection	Canceled	02/24/2022	02/21/2022	Canceled	Dean Evans
	EHINSP-559341	EH Well Grouting	Approved	02/24/2022	02/21/2022	Approved	Dean Evans
	EHINSP-559340	EH Well Head	Approved	02/24/2022	02/23/2022	Approved	Dean Evans
	EHINSP-551388	EH Well Record Received	Approved	12/29/2021	02/24/2022	Approved	EH Admin
3774-03							
WLS2008-00179	4426 RIDGE ST, CLAREMONT NC 200901060904415070	Well	Final	New Well		Robbie Phelps	12/09/2008
		EH Well Grouting	Approved	12/09/2008	12/09/2008	Approved	Robbie Phelps
	Done By: RP Notes:						
	INSP-144051	EH Well Head	Approved	03/03/2009	03/03/2009	Approved	Robbie Phelps
	INSP-144052	EH Well Record Received	Approved	12/29/2008	12/29/2008	Approved	EH Admin



CATAWBA COUNTY ENVIRONMENTAL HEALTH
NO GPS AT FINAL INSPECTIONS
BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>	<u>WORK CLASS</u>	<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
3780-03					
WELL-10-2016-077864	5334 MILLSTONE DR, CATAWBA NC 28609	Well	Final	New Well	Cheyenne Morgan 09/10/2020
EHINSP-490680	EH Well Head	Approved	09/10/2020	09/10/2020	Approved Cheyanne Morgan
EHINSP-490509	EH Well Record Received	Approved	09/09/2020	09/09/2020	Approved EH Admin
3790-03					
AUTH-12-2021-162960	6100 SHERRILLS FORD RD, CATAWBA NC 28609	Authorization to Construct	Final	New Septic	Jason Boyd 09/12/2022
EHINSP-591070	EH Septic Installation Checked 1st 3 trenches installed 92' 92' 102'	Approved	09/07/2022	08/12/2022	Approved Jason Boyd
EHINSP-591066	EH Septic Installation Checked Taylorsville precast 1500 gallon tank	Approved	09/07/2022	08/11/2022	Approved Jason Boyd
EHINSP-591076	EH Septic Installation Installed last 2 trenches 162' 152'	Approved	09/07/2022	08/17/2022	Approved Jason Boyd
3790-04					
WELL-04-2022-169010	6751 LONG ISLAND RD, CATAWBA NC 28609	Well	Final	New Well	Jason Boyd 04/19/2023
EHINSP-633312	EH Well Head	Approved	04/19/2023	04/19/2023	Approved Jason Boyd
EHINSP-627795	EH Well Record Received	Approved	03/22/2023	03/22/2023	Approved EH Admin
WELL-12-2021-162726	6762 LONG ISLAND RD, CATAWBA NC 28609	Well	Final	New Well	Jason Boyd 10/28/2022
EHINSP-563869	EH Well Grouting	Approved	03/25/2022	03/14/2022	Approved Jason Boyd
EHINSP-601985	EH Well Head Well variance received from state.	Approved	10/28/2022	10/28/2022	Approved Jason Boyd
EHINSP-600335	EH Well Head Well does not meet required 25' setback to detached garage. Well is 21' from garage. Called builder, Bobby Tucker, and advised he or the property owner to apply for a well variance with the state.	Failed	10/20/2022	10/20/2022	Failed Jason Boyd
EHINSP-569270	EH Well Record Received	Approved	04/28/2022	04/28/2022	Approved EH Admin



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>	<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
4606-01						
AUTH-06-2022-174316	4618 SAWGRASS CT, DENVER NC 28037	Authorization to Construct	Final	New Septic	Dean Evans	01/25/2023
	EHINSP-617201	EH GPS Data Collection	Canceled	01/25/2023	01/24/2023	Canceled Dean Evans
	EHINSP-617200	EH Septic Installation	Approved	01/25/2023	01/24/2023	Approved Dean Evans

4606-04						
AUTH-01-2022-163840	7883 VISTA VIEW DR, SHERRILLS FORD NC 28673	Authorization to Construct	Revoked	New Septic	Robbie Phelps	01/09/2023
	EHINSP-578873	EH Septic Installation checked tanks only	Approved	06/27/2022	06/17/2022	Approved Robbie Phelps

4607-01						
AUTH-05-2017-085084	7162 NANCY LEE CIR, SHERRILLS FORD NC 28673	Authorization to Construct	Revoked	New Septic	Jason Boyd	03/24/2020
	EHINSP-469511	EH Septic Installation	Failed	03/13/2020	03/11/2020	Failed Jason Boyd
	<p>Installer Avery Deweese with Dewey Septic #6196 out of Thomasville put in 25% reduction infiltrator chambers instead of 50% reduction panel block system as permitted. Also, the 50' buffer was not marked as noted in permit conditions and need to verify they have not installed inside 50' lake buffer. I had spoken with installer on Tuesday 3/10 about installation and reiterated that he would need to center feed trenches as that was what was required for panel block so line lengths would be less than 50'. Told him to hold off on installation of the system as it rained Tuesday morning at site. Spoke with installer on Wednesday 3/11 and he scheduled for 1 PM inspection. Told him in phone conversation to be sure to pay attention to foaming the inner seal of panels up half way and the outer seal all the way as required by T and J Panel for gravity panel block systems as he was a new installer. Upon arriving on site, I saw that they had installed 25% reduction. Asked installer for his copy of the permit which he could not provide. Said he had it on e mail on phone but could not show it to me when I asked. I had copy of the permit e mailed to me by Donna the other day and showed him where it was permitted for 50% reduction. Upon consultation on site with Installer, John Venable the general contractor, and Robbie Phelps, supervisor, it was determined we should have the buffer marked to verify setbacks. Chambers were removed and we will attempt to install horizontal panel blocks in same trenches as they require a 3' wide trench same as the 25% reduction. May need to dig trenches deeper to allow for product to have minimum 6" of cover. Advised installer and builder that rain will affect the time frame on installation of system.</p>					



CATAWBA COUNTY ENVIRONMENTAL HEALTH
NO GPS AT FINAL INSPECTIONS
BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>	<u>WORK CLASS</u>	<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>	
4607-12						
WELL-06-2017-086284	3595 STILL KNOLL LN, SHERRILLS FORD NC 28673	Well	Final	New Well	Jason Boyd	06/15/2017
EHINSP-362595	EH Well Grouting	Approved	06/15/2017	02/01/2017	Approved	Jason Boyd
EHINSP-362596	EH Well Head	Approved	06/15/2017	06/15/2017	Approved	Jason Boyd
EHINSP-362594	EH Well Record Received	Approved	06/15/2017	05/25/2017	Approved	EH Admin

4607-15						
AUTH-04-2020-130592	4032 RHYNLAND DR, SHERRILLS FORD NC 28673	Authorization to Construct	Final	New Septic	Jason Boyd	01/31/2022
EHINSP-533303	EH Septic Installation	Approved with notes	08/24/2021	08/13/2021	Approved with notes	Jason Boyd
	checked infiltrator plastic tank, plastic d box, and line 4 upper line from lake buffer					
EHINSP-533301	EH Septic Installation	Approved with notes	08/24/2021	08/12/2021	Approved with notes	Jason Boyd
	checked lines 2 and 3 up hill from lake buffer					
EHINSP-533299	EH Septic Installation	Approved with notes	08/24/2021	08/05/2021	Approved with notes	Jason Boyd
	Preconstruction conference with Charles Beatty and Mr Rhodes					
EHINSP-533300	EH Septic Installation	Approved with notes	08/24/2021	08/11/2021	Approved with notes	Jason Boyd
	checked line 1 closest to 50' lake buffer					




CATAWBA COUNTY ENVIRONMENTAL HEALTH
NO GPS AT FINAL INSPECTIONS
BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>		<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
4607-15							
AUTH-09-2020-138577	3943 CHEVLOT HILLS RD, SHERRILLS FORD NC 28673	Authorization to Construct	Final	New Septic		Jason Boyd	08/18/2021
EHINSP-532338	EH Septic Installation checked setbacks from deck to system	Approved		08/17/2021	08/06/2021	Approved	Jason Boyd
EHINSP-529235	EH Septic Installation	Follow Up Required		07/26/2021	07/16/2021	Follow Up Required	Jason Boyd
Checked Shoaf STB 760 tank and drain field.							
Deck has been added to footprint of home and was staked prior to installation of system							
Need to verify 5' setback to deck from drain field and tank prior to issuance of OP							
WELL-06-2022-174469	3837 CHEVLOT HILLS RD, SHERRILLS FORD NC 28673	Well	Final	Replacement		Blake Perkins	09/23/2022
EHINSP-582492	EH Well Grouting	Approved		07/18/2022	07/18/2022	Approved	Blake Perkins
EHINSP-587792	EH Well Head	Approved		08/17/2022	08/17/2022	Approved	Blake Perkins
EHINSP-585128	EH Well Record Received	Approved		08/04/2022	08/04/2022	Approved	EH Admin
WELL-08-2021-155915	4053 CHEVLOT HILLS RD, SHERRILLS FORD NC 28673	Well	Final	New Well		Jason Boyd	07/13/2022
EHINSP-570999	EH Well Grouting	Approved		05/10/2022	05/09/2022	Approved	Jason Boyd
EHINSP-581792	EH Well Head	Approved		07/13/2022	07/13/2022	Approved	Steven Price
EHINSP-573898	EH Well Record Received	Approved		05/27/2022	05/27/2022	Approved	EH Admin
4616-01							
WELL-03-2022-168616	4875 MOORE ST, SHERRILLS FORD NC 28673	Well	Final	Replacement		Cheyenne Morgan	03/29/2023
EHINSP-604935	EH Well Grouting	Approved		07/13/2022	07/13/2022	Approved	Cheyenne Morgan
EHINSP-629243	EH Well Head	Approved		03/29/2023	03/29/2023	Approved	Randy Ross
EHINSP-583671	EH Well Record Received	Approved		07/26/2022	07/26/2022	Approved	EH Admin
4616-03							



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>		<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
4616-03							
AUTH-01-2022-163987	5106 LEISURE LN, SHERRILLS FORD NC 28673	Authorization to Construct	Final	New Septic			04/27/2023
	EHINSP-636572	EH Electrical/Alarm	Approved	05/03/2023	04/04/2023	Approved	
	EHINSP-636570	EH Septic Installation	Approved	05/03/2023	04/04/2023	Approved	
	EHINSP-636571	EH Septic Pump Final	Approved	05/03/2023	04/04/2023	Approved	
AUTH-09-2021-157808	5202 GLENWOOD ST, SHERRILLS FORD NC 28673	Authorization to Construct	Revoked	New Septic		EH Admin	10/24/2022
	EHINSP-598387	EH Maintenance Contract Received	Approved	10/12/2022	10/12/2022	Approved	EH Admin
WELL-03-2021-146809	5101 MALLARD COVE, SHERRILLS FORD NC 28673	Well	Final	New Well		EH Admin	11/17/2021
	EHINSP-532212	EH Well Record Received	Approved	08/16/2021	08/16/2021	Approved	EH Admin
4617-01							
AUTH-04-2016-070732	8883 SHERRILLS FORD RD, SHERRILLS FORD NC 28673	Authorization to Construct	Final	Repairs		Robbie Phelps	05/10/2016
	EHINSP-324678	EH Electrical/Alarm	Approved	05/10/2016	05/03/2016	Approved	Robbie Phelps
	EHINSP-324677	EH Septic Installation	Approved	05/10/2016	05/03/2016	Approved	Robbie Phelps
	EHINSP-324679	EH Septic Pump Final	Approved	05/10/2016	05/03/2016	Approved	Robbie Phelps
4617-03							
WELL-03-2016-070480	4204 MCGEE POINT RD, TERRELL NC 28682	Well	Final	Replacement		Jason Boyd	12/29/2016
	EHINSP-346043	EH GPS Data Collection	Follow Up Required	12/29/2016	12/29/2016	Follow Up Required	Jason Boyd
	EHINSP-326429	EH Well Grouting	Approved	05/27/2016	05/26/2016	Approved	Robbie Phelps
	EHINSP-346042	EH Well Head	Approved	12/29/2016	12/29/2016	Approved	Jason Boyd
	EHINSP-326392	EH Well Record Received	Approved	05/26/2016	05/26/2016	Approved	EH Admin



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>	<u>WORK CLASS</u>	<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
4617-04					
AUTH-02-2016-068947	3926 CEDAR WOOD TR, TERRELL NC 28682	Authorization to Construct	Final New Septic	Jason Boyd	10/12/2016
EHINSP-331379	EH GPS Data Collection	Follow Up Required	07/22/2016 07/15/2016	Follow Up Required	Jason Boyd
EHINSP-331380	EH Septic Installation	Follow Up Required	07/22/2016 10/12/2016	Follow Up Required	Jason Boyd
Checked Dellinger tanks, set pressure head with WEO 17 Goulds pump, checked drain field with FJ Ervin installer #2968 on 7/15/16 **** Need certified operator contract and to check alarm prior to issuance of OP. Called builder Shaun Ogden and told him this after inspection**** Received contract 10-12-16					

4617-14					
WELL-10-2016-077560	3920 MCGEE POINT RD, TERRELL NC 28682	Well	Final New Well	Robbie Phelps	01/04/2017
EHINSP-346444	EH Well Grouting	Approved with notes	01/04/2017 12/28/2016	Approved with notes	Robbie Phelps
Well driller self certified on 12/23/16. Well driller assumes all liability					
EHINSP-346445	EH Well Head	Approved	01/04/2017 01/04/2017	Approved	Robbie Phelps
EHINSP-346446	EH Well Record Received	Approved	01/04/2017 01/04/2017	Approved	EH Admin

4619-01					
WELL-12-2018-108761	1439 LANGDON RD, SHERRILLS FORD NC 28673	Well	Final Replacement	Robbie Phelps	08/18/2023
EHINSP-604916	EH Well Grouting	Approved	11/14/2022 01/24/2019	Approved	Robbie Phelps
EHINSP-658843	EH Well Head	Approved	08/18/2023 07/17/2023	Approved	Bryan Forsee
EHINSP-421760	EH Well Record Received	Approved	02/06/2019 02/06/2019	Approved	EH Admin

4627-05



CATAWBA COUNTY ENVIRONMENTAL HEALTH
 NO GPS AT FINAL INSPECTIONS
 BY PARCEL PREFIX BY PERMIT#

<u>PERMIT#</u>	<u>ADDRESS</u>	<u>PERMIT TYPE</u>		<u>WORK CLASS</u>		<u>INSPECTOR NAME</u>	<u>FINALED DATE</u>
4627-05							
WELL-12-2021-162933	3532 OSPREY CT, TERRELL NC 28682	Well	Final	New Well		Randy Ross	06/14/2023
	EHINSP-645684	EH Well Head	Approved	06/14/2023	05/30/2023	Approved	Randy Ross
	EHINSP-623039	EH Well Record Received	Approved	02/24/2023	02/24/2023	Approved	EH Admin
4700-02							
AUTH-08-2023-203812	7836 LONG ISLAND RD, CATAWBA NC 28609	Authorization to Construct	Final	Repairs		Bryan Forsee	10/17/2023
	EHINSP-671502	EH Septic Installation	Approved	10/17/2023	10/09/2023	Approved	Bryan Forsee
WLS2009-00600A	1675 BAY HEAD CT, CATAWBA NC	Authorization to Construct	Final	New Septic		Megen McBride	05/03/2017
	INSP-131828	EH Consultative Contact	Approved with notes	10/20/2009	10/20/2009	Approved with notes	Megen McBride
	JASON AND I MET ON SITE WITH GARY JOHNSON (SEPTIC INSTALLER #3604) SEPTIC AREA HAS BEEN CLEARED OF TREES. WE LAID OUT DRAINFIELD 25% REDUCTION INITIAL SYSTEM WILL FIT.						
	EHINSP-357549	EH Electrical/Alarm	Approved	04/28/2017	04/27/2017	Approved	Jason Boyd
	INSP-131829	EH Septic Installation	Follow Up Required	10/30/2009	10/30/2009	Follow Up Required	Megen McBride
	MM INSPECTED TANKS TP-1000-STB-182.. TP-1000-TP-17 TAYLORSVILLE PRE-CAST						
	INSP-131839	EH Septic Installation	Approved with notes	11/03/2009	11/03/2009	Approved with notes	Jason Boyd
	JB INSPECTED DRAINFIELD AND PRESSURE MANIFOLD						
	EHINSP-357548	EH Septic Pump Final	Approved	04/28/2017	04/27/2017	Approved	Jason Boyd
4710-03							
AUTH-01-2020-126835	8486 MONBO RD, CATAWBA NC 28609	Authorization to Construct	Final	New Septic		Jason Boyd	10/12/2020
	EHINSP-492800	EH Septic Installation	Approved	09/30/2020	09/16/2020	Approved	Jason Boyd
	system shot in with installer Shannon Henderson #1091						
	EHINSP-492801	EH Septic Installation	Approved	09/30/2020	09/21/2020	Approved	Jason Boyd
	checked installation 5 x 50' PB , STB 760 Shoaf tanks						